

PURCHASING DEPARTMENT

140 STONEWALL AVENUE WEST, STE 204
FAYETTEVILLE, GEORGIA 30214
PHONE: 770-305-5420
www.fayettecountyga.gov

August 24, 2015

Subject: #1012-B, Sports Lighting for Kiwanis Park Field #9 - Addendum #1

Dear Gentlemen/Ladies:

Included herein is additional information and clarification for the above referenced Invitation for Bids. Please consider all of this information when preparing your bid.

- 1. Clarify Transformer specification?
 The Transformer is a single phase 240 / 480 / 3 wire. 1 wire to ground is 240 volts, two wires to ground is 480 volts.
- 2. Clarify scoreboard electrical specification on fields 2 and 4? The existing electrical for scoreboards shall remain for fields 2 and 4.

Received by	Company

Note: If this addendum is not returned to the Fayette County Purchasing Department or if it is returned not signed, <u>all</u> responders shall still be responsible for the requirements of this addendum and the specifications or changes herein.

The opening date for this invitation for bids has changed. The <u>new</u> opening date is: 3:00p.m. Wednesday, September 2, 2015. Bids must be received in the Purchasing Department at the address above in Suite 204 on or before the new opening date and time.

Thank you for your attention to this matter.

Sincerely,

Ted L. Burgess

Director of Purchasing

TLB/tcb